

ANNEXURE-II to G.O.Ms.No.52, Public Works Department, dated 2.3.2012.

- 1) G.O.(Ms). No. 1766, Public Works Department , dated 31.10.1988.
- 2) G.O.(Ms). No. 213, E&F (EC-1) Department , dated 30.03.1989.
- 3) G.O.(Ms). No. 281, Public Works Department , dated 3.4.1996.
- 4) G.O.(Ms). No. 127, E&F (suga -3) Department , dated 8.5.1998.
- 5) Other spacing norms which are approved in the State Level Committee for Re-Estimation of Ground Water Assessment under the Chairmanship of the Secretary to Government / Public Works Department, held on 10.2.2011 and adhering by State Ground and Surface Water Resources Data Centre, the distance between two wells such as (1) Two dug wells – 150m; (2) Two shallow tube wells – 175m; (3) Two filter points – 175m; (4) Two dug cum bore wells – 175m; (5) Two medium tube wells – 600m; (6) Two deep tube wells-600m; (7) Medium tube well and deep tube well – 600m; (8) Shallow tube well & medium tube well – 387.5m; (9) Dug well and shallow tube well – 162.5m; (10) Dug well & medium tube well – 375m; (11) Dug well and deep tube well 375m are to be adhered. The depth of shallow tube well / filter point is, depth upto 100m below ground level, medium tube well depth is 100 to 250m below ground level and deep tube well is depth more than 250m.
- 6) Other technical circulars issued by the Chief Engineer / State Ground and Surface Water Resources Data Centre in this regard as and when, are to be adhered.

**M.SAI KUMAR
SECRETARY TO GOVERNMENT**

/FORWARDED BY ORDER/

**Sd/-
SECTION OFFICER.**